

DESIGN:

All new construction and upgrades having an OGI requirement shall be constructed to include a sample monitoring station.

Facilities required to install OGIs and/or sample monitoring stations shall install units of approved designs on file with the City's *Construction Standards*.

If an existing undersized unit is structurally sound and installed properly, then, in lieu of replacing it with a larger unit, the owner may choose to install an additional unit in series with the existing unit to satisfy the total size capacity required.

All required OGIs shall be installed and properly maintained with all internal required plumbing of proper design and length in place at all times.

Revised 08/20/2002